

D

C

B


A

D

C


B

A



208VAC
6 CIRCUIT
20AMPS MAX

PINOUT: P19-04
1 = H CKT 1
2 = H CKT 1
3 = H CKT 2
4 = H CKT 2
5 = H CKT 3
6 = H CKT 3
7 = H CKT 4
8 = H CKT 4
9 = H CKT 5
10 = H CKT 5
11 = H CKT 6
12 = H CKT 6
13-19 = GROUND RING



BRANCH POWER
19 PIN 6 CIRCUIT 208V
PNL6 Connector 1-6 (Left)
CIRCUIT 1

PNL6 Connector 1-6 (Right)
CIRCUIT 1

PNL6 Connector 1-6 (Left)
CIRCUIT 2

PNL6 Connector 1-6 (Right)
CIRCUIT 2

PNL6 Connector 1-6 (Left)
CIRCUIT 3

PNL6 Connector 1-6 (Right)
CIRCUIT 3

PNL6 Connector 1-6 (Left)
CIRCUIT 4

PNL6 Connector 1-6 (Right)
CIRCUIT 4

PNL6 Connector 1-6 (Left)
CIRCUIT 5

PNL6 Connector 1-6 (Right)
CIRCUIT 5

PNL6 Connector 1-6 (Left)
CIRCUIT 6

PNL6 Connector 1-6 (Right)
CIRCUIT 6

BRANCH POWER
19 PIN 6 CIRCUIT 208V
PNL7 Connector 7-12 (Left)
CIRCUIT 1

PNL7 Connector 7-12 (Right)
CIRCUIT 1

PNL7 Connector 7-12 (Left)
CIRCUIT 2

PNL7 Connector 7-12 (Right)
CIRCUIT 2

PNL7 Connector 7-12 (Left)
CIRCUIT 3

PNL7 Connector 7-12 (Right)
CIRCUIT 3

PNL7 Connector 7-12 (Left)
CIRCUIT 4



PNL7 Connector 7-12 (Right)
CIRCUIT 4

PNL7 Connector 7-12 (Left)
CIRCUIT 5

PNL7 Connector 7-12 (Right)
CIRCUIT 5

PNL7 Connector 7-12 (Left)
CIRCUIT 6

PNL7 Connector 7-12 (Right)
CIRCUIT 6



BRANCH POWER
19 PIN 6 CIRCUIT 208V
PNL8 Connector 13-18 (Left)
CIRCUIT 1

PNL8 Connector 13-18 (Right)
CIRCUIT 1

PNL8 Connector 13-18 (Left)
CIRCUIT 2

PNL8 Connector 13-18 (Right)
CIRCUIT 2

PNL8 Connector 13-18 (Left)
CIRCUIT 3

PNL8 Connector 13-18 (Right)
CIRCUIT 3

PNL8 Connector 13-18 (Left)
CIRCUIT 4

PNL8 Connector 13-18 (Right)
CIRCUIT 4

PNL8 Connector 13-18 (Left)
CIRCUIT 5

PNL8 Connector 13-18 (Right)
CIRCUIT 5

PNL8 Connector 13-18 (Left)
CIRCUIT 6

PNL8 Connector 13-18 (Right)
CIRCUIT 6

REV	DESCRIPTION	Date	APPROVED
A	WAS 1302-PACIFIC-072915. JK 2/2/18	2/6/18	DC



520 FURNACE DOCK ROAD
CORTLANDT MANOR, NY 10567
(914) 786-8677

TITLE:
SCHEMATIC

SIZE D	Checked By: CT	DWG NO. 1300-200A-12-2-49	REV B
Drawn By: JK		Sheet 1 OF 1	