

LENGTHS

CIRCUIT 1 - 6 FT


CIRCUIT 2 - 8 FT

CIRCUIT 3 - 10 FT


CIRCUIT 4 - 12 FT

CIRCUIT 5 - 14 FT

CIRCUIT 6 - 16 FT



Installed Amtec Cord
Grip #2201-020
see above image




CABLE SPEC: 12 AWG, 3 CONDUCTOR,
TYPE SJOOW, 300V, 90°C


PINOUT DESIGNATION: P19-02		
PIN ID		PIN FUNCTION
L1	1	CIRCUIT 1 HOT
N1	2	CIRCUIT 1 NEUTRAL
L2	3	CIRCUIT 2 HOT
N2	4	CIRCUIT 2 NEUTRAL
L3	5	CIRCUIT 3 HOT
N3	6	CIRCUIT 3 NEUTRAL
L4	7	CIRCUIT 4 HOT
N4	8	CIRCUIT 4 NEUTRAL
L5	9	CIRCUIT 5 HOT
N5	10	CIRCUIT 5 NEUTRAL
L6	11	CIRCUIT 6 HOT
N6	12	CIRCUIT 6 NEUTRAL
L1 GROUND	13	CIRCUIT 1 GROUND
L2 GROUND	14	CIRCUIT 2 GROUND
L3 GROUND	15	CIRCUIT 3 GROUND
L4 GROUND	16	CIRCUIT 4 GROUND
L5 GROUND	17	CIRCUIT 5 GROUND
L6 GROUND	18	CIRCUIT 6 GROUND
CENTER PIN	19	GROUND RING

CIRCUIT ID LABEL HERE ON EACH TAIL

PART NUMBER/FOOTAGE LABEL
ONLY CIRCUIT 1 GETS THIS LABEL



COPYRIGHT ©2006 MOTION LABORATORIES, INC. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE EXCLUSIVE, CONFIDENTIAL PROPERTY OF MOTION LABORATORIES, INC. AND IT SHALL NOT BE REPRODUCED, COPIED, OR USED FOR ANY PURPOSE WHATSOEVER, UNLESS, AND STRICTLY TO THE EXTENT, SUCH IS EXPRESSLY AUTHORIZED BY MOTION LABORATORIES, INC. IN WRITING.



motion laboratories
520 Furnace Dock Rd Cortlandt Manor, NY 10567
1 800 227-6784 P 914 788-8877 F 914 788-8866

Part No.

1404-02-26-99-017

Drawn by
DH

Date
7/1/14

Rev
C

Rev	Date	By	Description

Customer	EAW
Contact	
Phone	
Fax	